



A	B	C	D	F	G	H	I	J	K	L	M	N	O	P	Q
2 OEM design points:				Off-design conditions:				stn#	Gas calculation	kpa	k	m³/kg	R	cp gamma	
3	Engine model	9171E		actual fuel apply	diesel-6	0	ISO standard air	101	288	0.825	288	1.009	1.400		
4	shaft speed:rpm	3000		site ambient:kpa	101.3		ambient air inlet	101	306	0.905	292	1.027	1.396		
5	ISO std-p:kpa	101.3		site amb temp:ot	33	1	air filter outlet	100	306	0.915	292	1.027	1.396		
6	ISO std-t:°C	15		relative humidity	85%		compressor inlet	100	306	0.917	292	1.027	1.396		
7	ISO std RH:	60%		vapor / air:kg/kg	0.027		compressor exit	1230	664	0.162	292	1.0957	1.3628		
8	vapor/air:kg/kg	0.006				2	air exit diffuser	1228	664	0.162	292	1.096	1.363		
9	design flow:kg/s	407.0		Actual test corrections:				combustor zone	1222	1397	0.340	297	1.304	1.295	
10	compress-ratio:	12.30		air inlet filter Δp	1.0%	3	deNOx water in	1222	1397	0.340	297	1.304	1.295		
11	turbine firing t:°C	1124		engine intake Δp	0.3%		combustor exit	1215	1397	0.341	297	1.304	1.295		
12	turbine exit t:°C	538		compr-exit Δp	0.2%		turbine SOT exit	1215	1348	0.329	297	1.304	1.295		
13	ISO output:kWe	126040		combustor Δp	0.5%	4	turbine b/f cool	104	831	2.364	297	1.1890	1.3330		
14	heat rate kj/kWh	10460		exhaust exit Δp	3.0%		turbine aft cool	104	829	2.360	297	1.064	1.387		
15	compress stages:	17		actual cmpr pr	12.14	5	turbine exhaust	104	827	2.354	297	1.064	1.387		
16	stage pr-ratio:	1.159		actual turbine pr	11.635										
17	polytropic eff:	0.863		actual fuel ratio	0.023		Flow parameter								
18	turbine pr-ratio:	12.30		actual cmpr eff	0.863	2	comp 1st stage	0.58	33.00	1.980	199	322	1.023		
19	turbine stages:	3		actual turb eff	0.863	3	comp last stage	0.16	10.81	0.672	82	295	0.939		
20	stage pr-ratio:	2.308		actual cmbtr eff	0.999		combust zone1	0.02	1.42	2.208	19	0	0.838		
21	polytropic eff:	0.863		actual mech eff	0.993		combust zone2	0.10	6.81	1.593	51	0	0.914		
22	specified fuel	methane		actual altern eff	0.986	4	turbine 1st stage	0.16	10.10	1.061	112	335	1.068		
23	CH ₄ LHV:kj/kg	49997		actual flow:kg/s	373.5	5	turbine last stage	0.50	28.95	3.563	281	405	1.290		
24	fuel/air ratio:	0.019													
25	fuel/H ₂ O fwd:kpa	1323		engine cooling coef:				data evaluation			comp turbine		combustor evaluation		
26	fuel fwd temp:°C	56		total cmpr bleed	0.0713		isentropic ETA:	0.814	0.896		inner comb vol:n	0.037			
27	mechanical eff:	0.993		cmpr to stage3	0.0060		ref Tm gamma:	1.3628	1.3330		outer comb vol:n	0.096			
28	combustor eff:	0.999		cmpr to stage2	0.0063		ref Tmean cp:	1.0957	1.1890		zone-1 flow:kg/s	77.4			
29	alternator eff:	0.986		cmpr to stage1	0.0590						zone-2 flow:kg/s	57.7			
30	Engine cooling ceof:			nett cmbt inlet	0.9287		Engine sizing			comp turbine		zone-3 flow:kg/s		219.7	
31	total cmpr bleed	0.0713		total cmbt exit	0.9498		rotor-φ/blade-h	mm	mm		Performance Analysis:				
32	cmpr to stage3	0.0060					1st stage hub	1775	1974		cmpr work:kWs	146977			
33	cmpr to stage2	0.0063		Optional BOP functions:				1st stage pitch	2087	2154		turb power:kWs	250731		
34	cmpr to stage1	0.0590		deNOx H ₂ O:kg/s	0		1st stage tip	2400	2334		net power:kWe	103755			
35	nett cmbt inlet	0.9287		H ₂ O/air:kg/kg	0.0000		1st stage blade	312	180		fuel flow rate:kg/	7.889			
36	total cmbt exit	0.9463		dN-H ₂ O:kj/kgk	4.2105		last stage hub	1787	2112		fuel rate:kg/kWh	0.274			
37	Off-design GT exh flow			Off-design GT exh energy				last stage pitch	1915	2603		heat efficiency:	0.320		
38	exh gas:kg/kg	57.8		exh heat:kj/kg	782		last stage tip	2043	3093		heat rate:kj/kWh	11250			
39	exh air:kg/kg	57.5		exh energy:kj/s	298591		last stage blade:	128	490						
40	exh flow:kg/s	381.4		engine thrust:N	122820										



A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q			
54	HRSG-Dual Pressure (non RH); forced circulation-vertical flue flow; single steam flow-HP-exh mix LP-new to LP turbine																		
55	GT exhaust parameter																		
56	HRSG flue gas flow parameters & steam evaporation calculations:																		
56	gt exit flow: kg/s	381.4	<steam phase >>										<gas phase >>			m-flow			
57	gt exit temp: °C	553.9	Heat exchange:	p:kpa	t:°C	st:kj/kg	liq:kj/kg	Q:kj/s	TP:°C	TP:kj/kg	ex:kj/kg	exit:°C	m:kg/s						
58	gt exit enth:kj/kg	781.7	HP sphtr-1	10674	523.6	3426.6		12167	553.9	656.8	752.3	634.5	69.79						
59	HRSG design analysis:																		
59	HP sphtr-2	11208	460.0	3252.3			38960	634.5	765.6	658.3	545.6								
60	heat transf eff	92.0%	HP evaporator	11768	323.2	2694.0	1482.3	92458	331.2	372.4	435.3	387.0	69.79						
61			HP economizer	12356	305.0		1369.1	47998	379.1	431.2	316.3	278.0							
62	HP design p&t profile: rated:																		
62	LP superheater	552.7	283.7	3029.6			1344	387.0	441.2	432.1	379.1	4.98							
63	HP sph1:kpa	10674	10674	LP evaporator	663.2	162.8	2759.7	687.6	10681	184.8	201.4	290.5	266.6	4.98					
64	HP sph1:°C	523.6	523.6	LP economizer	3200.0	161.0		681.3	39893	183.0	199.4	194.3	178.3	74.77					
65	sph1-appro:Δt°C	30.3	76.0	Deaerator	594.0	146.0		615.0	flue gas discharge temp:				88.838						
66	sph1:sph2 Δkpa	5.0%	NA	bfwp inlet	5.71	35.3		147.7	Energy:Q=kj/s				HP	LP	Total				
67	HP sph2:kpa	11208	NA	Evaporation				HP	LP	Total	energy utilized				143585	60023	243501		
68	HP sph2:°C	460	460	Output:kg/hr				251227	17929	269155	counter balance				143585	60023	243501		
69	sph2-appro:Δt°C	174.5	125																
70	hpev>sph Δkpa	5.0%	NA	HRSG flue & steam/water flows press/temp															
71	HP evap:kpa	11768	NA																
72	HP evap:°C	323.2	319																
73	hpev-pinch:Δt°C	8	8																
74	hpec>evap Δkpa	5.0%	NA																
75	HP econ:kpa	12356	NA																
76	HP econ-exit:°C	305.0	305																
77	hpec-appro:Δt°C	74.1	12																
78	LP design p&t profile:																		
79	LP sph:kpa	552.7	552.7																
80	LP sph:°C	283.7	283.7																
81	lpsh-appro:Δt°C	103.3	38																
82	lpev>sph Δkpa	20.0%	NA																
83	LP evap:kpa	663.2	NA																
84	LP evap:°C	162.8	NA																
85	lpev-pinch:Δt°C	22.0	7.4																
86	Deaerator:kpa	594	594																
87	Deaerator:°C	146	146																
88	LP econ:kpa	3200	NA																
89	LP econ-exit:°C	161	NA																
90	lpec-appro:Δt°C	105.6	20																
91																			
92	Steam turbine design:																		
93	HP stm inlet:kpa	10515	10515																
94	HP stm inlet:°C	520.0	530.6	attemperation:															
95	LP stm inlet:kpa	482.2	482.2	rate 0.0%															
96	LP stm inlet:°C	280.0	285.6	t:°C 522															
97	LP stm exh:kpa	5.71	8	kpa 10674															
98	LP stm exh:°C	35.3	NA	kj/kg 3419															
99	Stm turbine efficiency:																		
100	HP turbine	0.88	NA	blow down:															
101	LP turbine	0.845	NA	HP rate 0.0%															
102	mechanical	0.993	NA	LP rate 0.0%															
103	alternator	0.99	NA																
104	exh loss:kj/kg	56	NA																
Diagram: HRSG flue & steam/water flows press/temp																			
HRSG liq/stm states:																			
Cdn fw-in:kj/kgk 0.5087																			
LP-econ in:°C 35.4																			
LP-econ:kj/kgk 1.9494																			
D/A inlet:°C 158.4																			
D/A liq-s:kj/kgk 1.9269																			
LP evap in:°C 158.5																			
LP evap:kj/kgk 1.9269																			
LP evap sat:°C 162.8																			
HP econ in:°C 159.8																			
HP econ:kj/kgk 3.2878																			
HP econ out:°C 305.0																			
HP evap in:°C 304.7																			
HP evap sat:°C 323.2																			
Turbine steam states																			
HP stm-in:kj/kg 3419.3																			
HP exh stm:kpa 526.0																			
HP exh stm:°C 153.8																			
HP exh-h:kj/kg 2749.8																			
HP exh-s:kj/kgk 6.802																			
HP isen-δh:kj/kg 2735.5																			
correct θh:kj/kg 2821.0																			
LP stm-in:kj/kg 3023.9																			
Hp+Lp mix:kj/kg 2834.5																			
LP stm-in:°C 190.0																			
LP exh-s:kj/kgk 7.031																			
LP isen-δh:kj/kg 2264.2																			
correct θh:kj/kg 2381.9																			
Steam turbine proper output																			
kWe HP LP Total																			
design 40880 29031 69911																			
actual 40880 29031 69911																			
GTCC Performance Evaluation																			
performance design actual																			
power kW: 173665 173665																			
heat rate kj/kWh 6721 6721																			
combine heat eff 0.536 0.536																			
heat recovery efl 0.816 0.816																			
circulating water flow																			
CW inlet t°C 23																			
CW in/out Δt 8																			
CW exit t°C 31																			
CW flow kg/s 5255																			

R	S	T	U	V	W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH
2	Fuel analysis		Heat formation Δh_f table				Combustion reaction stoichiometric				Fluegas content by wt					
3	carbon	0.871	mole	mol wt	kJ/mol			mole	C_xH_y	C_xH_yO_z	C_xH_yN_z	C_xH_yS_z	second argument	temp		
4	hydroge	0.100	C	12.01	-717			C	13.0	3.0	4.0	4.0	reference temp	25.56		
5	oxygen	0.000	CO ₂	44.01	394			H	17.9	6.0	4.0	4.0	reference press	101.56		
6	nitrogen	0.000	H	1.01	-218			O		1.0			zero enthalpy temp	0.01		
7	sulfur	0.021	H ₂ O(l)	18.02	286			N			2.0		gas mixture % by weight			
8	moisture	0.005	H ₂ O(g)	18.02	242			S				1.0	carbon dioxide	0.035		
9	ash	0.003	O	16.00	-249			O ₂	17.5	4.0	9.0	6.0	atmospheric nitro	0.748		
10	total	1.000	N	14.01	-473			CO ₂	13.0	3.0	4.0	4.0	oxygen	0.152		
11	Combustibles		NO ₂	46.01	-33			H ₂ O	8.9	3.0	2.0	2.0	sulfur dioxide	0.000		
12	carbon	0.8777	S	32.06	-276			NO ₂			2.0		water vapor	0.066		
13	hydroge	0.1012	SO ₂	64.12	297			SO ₂				1.0	total	1.000		
14	nitrogen	0.0000	C ₄ H ₄ N ₂	80.09	140			Molecular ratio		Combustion Analysis		Fuel fluegas analysis				
15	sulfur	0.0212	C ₄ H ₄ S	84.14	81			H	C	std air mole wt	28.97	gas	m ³ /kg			
16	total	1.0000	fuel	177.91	245			0.1004	0.0731	O ₂ fraction in air	0.21	CO ₂	1.6253			
17	Fuel-bond N₂/S		Benson Δh_f		245			H/C	1.3735	fluegas constant	297	N ₂	8.2743			
18	C ₄ H ₄ N ₂	0.0000	group <cal/mol	kJ/mol				17.86	13.00	theoret-air kg/kg	13.57	SO ₂	0.0147			
19	C ₄ H ₄ S	0.0555	P: CH ₃	10.01	41.91			N	S	prime zone t:k	2451	H ₂ O	0.1798			
20	Heating value		S: CH ₂	4.99	20.89			0.0000	0.0007	2nd-zone t:k	1603	theoret-flue	10.094			
21	HHV	43318	T: CH	2.03	8.50			N/C	S/C	3rd zone t:k	1397	prime flue	14.108			
22	LHV	41099	Q: C	0.12	0.50			0.0000	0.0090	prime excess air	1.383	final actual flue	33.552			
23								N mole	S mole	2nd excess air:	1.856	theoret-air/flue	10.474			
24								0.0000	0.1174	total excess air:	3.240					
25	Engine design point evaluation (ISO CH₄)															
26	gas R	mT-cp	cp/cv	stg-pr	isen-eff	inlet-p	exit-p	inlet-T	exit-T	Combustor design/off-design points						
27	Compr	288	1.102	1.398	1.159	0.810	101	1246.3	288	658	design point		off-design			
28	Turbine	292	1.191	1.326	2.308	0.897	1246	101	1397	821	zone	inner	outer	inner	outer	
29											Load	1.500	1.500	1.500	1.500	
30	Engine	compressor	turbine rotor	Combustor	θair	z1-Xair	z2-Xair									
31	stage	1st	last	1st	last	gas state	17.235	1.305	1.780	Mach	0.020	0.100	0.020	0.100		
32	Load	0.223	0.265	2.000	1.370	flame-T	SOT	LHV	FAR	flow:Q	1.432	6.868	1.421	6.814		
33	pr coef	1.085	0.878	0.440	0.510	2472	1397	49997	0.0188	A:m ²	2.614	1.154	2.197	1.098		
34	flow Q	33.31	10.87	10.18	29.25					V:m/s	20	51	19	51		
35	sizing	1st	last	1st	last	combustor flow	design	off-des		flow:	163	222	135	220		
36	A:m ²	2.047	0.770	1.221	4.008	intensity:kW/m ³	24363	24436		vol:m ³	0.500	1.185	0.419	1.100		
37	Rhub	0.888	0.893	0.987	1.056	zone-1 flow:kg/s	71.9	77.4		radius:m	0.912	0.963	0.836	0.889		
38	Rpitch	1.044	0.957	1.077	1.301	zone-2 flow:kg/s	70.1	57.7		length:m	0.549	1.231	0.501	1.237		
39	Rtip	1.200	1.021	1.167	1.546	zone-3 flow:kg/s	265.0	219.7		time:sec	0.028	0.024	0.026	0.024		
40	blade	0.312	0.128	0.180	0.490					Fluegas NO_x emission Calculation						
41	hub/tip	0.740	0.875	0.845	0.683	Off-design engine speed evaluation					theroret-air kg/kg per LHV	13.487				
42						compressor		turbine rotor		theroret-air m ³ /kg per LHV	10.431					
43	speed	1st	last	1st	last	stage	1st	last	1st	last	fluegas kg/kg per LHV	14.487				
44	Mach	0.58	0.16	0.15	0.50	pr coef	1.085	0.878	0.440	0.510	fluegas m ³ /kg per LHV	11.073				
45	V:m/s	192	81	113	277	Mach	0.58	0.16	0.16	0.50	fluegas density kg/m ³	1.3083				
45	V/Upit	0.59	0.27	0.33	0.68	V/Upit	0.62	0.28	0.33	0.69	primary combustion					
47	Uhub	279	281	310	332	Uhub	279	281	310	332	prime flugas NO _x kg/kg	0.0021				
48	Upitch	328	301	338	409	Upitch	322	295	335	405	prime flugas NO _x mg/m ³	149.70				
49	Utip	377	321	367	486	Utip	377	321	367	486	final combustion					
50	reMhub	0.80	0.57	0.45	0.77	reMhub	0.80	0.57	0.45	0.76	final fluegas NO _x kg/kg	0.005				
51	reMpit	0.86	0.61	0.48	0.88	reMpit	0.85	0.60	0.48	0.87	final fluegas NO _x mg/m ³	149.70				
52	reMtip	0.94	0.64	0.52	1.00	reMtip	0.94	0.64	0.53	0.98						